



---

**EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO**

**EULEX KOSOVO**

Ndertesë Farmëd  
"Muharrem Fejza" p.n.  
Lagja e Spitalit  
10000 Pristina, Kosovo  
Tel: +386 (0)43 78 2000  
[www.eulex-kosovo.eu](http://www.eulex-kosovo.eu)

**CLARIFICATIONS No. 2**

**PUBLICATION REFERENCE: EuropeAid/129294/D/SUP/XK  
Framework Contract for the Fire Alarm System**

**1. Questions regarding the Technical Specification**

Question No	Lot No	Question	Answer
1.	Lot 1	Fire Detection System, - Should all Fire Alarm Control Panel's (FACP) be monitored form HQ (centralized monitoring system for all FACP to one location) or each FACP is it going to be independent form each other? - If yes than which is the connectivity access to each location.	Each Fire Alarm Control Panel (FACP) will be independent from each other.