



EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO

EULEX KOSOVO

Ndertesa Farmed

“Muharrem Fejza” p.n.

Lagja e Spitalit

10 000 Pristina, Kosovo

Tel: + (386) 43 78 2000

<http://www.eulex-kosovo.eu>

CLARIFICATIONS (6)

PUBLICATION REFERENCE: EuropeAid/128789/D/SUP/KOS/ Framework Contract for Security Upgrade

1. Questions regarding Technical Specifications

No	Item No/ & NO.	Question	Answer
1	Lot 13	You say in Mandatory Requirements, Part 6-Engine, “The fuel injection pump shall be fitted with a <u>mechanical governor</u> ”. However in the technical specifications of 50 kva Generator, you request “Governor Type: <u>Electronic</u> .” So must we supply governor type as electronic or mechanic?	Mandatory Specifications 6. Engine Instead of: “The fuel injection pump shall be fitted with a mechanical governor...” Should read: electronic
2	Lot 13	You say in Mandatory Requirements, Part 6-Engine, you request 24 Volt starting batteries. However in Part VIII, Control Interfaces for Remote Monitoring, you request 12 VDC for 50 and 110 kVA gensets. So there is a contradiction between Mandatory Requirements and Technical Specifications.	For 50 kva and 110 kva the requirement 12 VDC is correct. For 160 kva and 250 kva the requirement is 24 Volt.