



EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO

EULEX KOSOVO

Ndertesë Farmëd
"Muharrem Fejza" p.n.
Lagja e Spitalit
10000 Pristina, Kosovo
Tel: +386 (0)43 78 2000
www.eulex-kosovo.eu

CORRIGENDUM NUMBER 2
TO THE TENDER DOSSIER

PUBLICATION REFERENCE: EuropeAid/128789/D/SUP/KOS/ Framework
Contract for Security Upgrade

A) The following corrections are made to the Annex II+III Technical Specifications:
Lot 13: Generator

Item 2: Technical Specifications for 110 kva Generator (3- Phase)

Previous text:

Fuel tank Capacity LT: **358**

Shall read now:

Fuel tank Capacity LT: **150**

1. Mandatory Specifications

12. Control Panel

IV. Engine Status Monitoring.

Previous text:

The following information shall be available from an **analog** display status panel on the generator set control:

Shall read now:

The following information shall be available from an **analog or digital** display status panel on the generator set control:

All other terms and conditions of the Tender Dossier remain unchanged. The above alterations and /corrections to the Tender Dossier are integral part of the Tender Dossier.

Please regularly check Europaid and/or EULEX Website where additional clarifications may be published until **11th February 2011** on:

Europeaid Web: <https://webgate.ec.europa.eu/europeaid/online-services/index.cfm?do=publi.welcome&nbPubliList=15&orderby=upd&orderbyad=Desc&searchtype=RS&aofr=128789>

EULEX Web: <http://www.eulex-kosovo.eu/en/tenders/065-security-upgrade.php>