



**EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO
EULEX KOSOVO**

Ndertesë Farmëd
"Muharrem Fejza" p.n.
Lagja e Spitalit
10000 Pristina, Kosovo
www.eulex-kosovo.eu

Corrigendum No. 3 to the Tender Dossier
EuropeAid/131105/D/SUP/XK, Supply of Containerized Data Center
(PROC/258/11)

The following changes have been introduced to Annex II+II Technical Specifications namely,

General specifications:

Previous text:

1.2.4. Doors

- Door dimensions:
 - Equipment double door: 2000x2600 mm (WxH)
 - Personal single door: 900 x 2100 mm (WxH)

Shall read now:

- Equipment double door: **at least 2100x1600 mm (HxW)**
- Personal single door: **at least 2100 x 900 mm (HxW)**

General specifications:

Previous text:

- Container module size: 12,192m x 3,3m x 2.896m (LxWxH) (internal dimensions: 11,85m x 3m x 2,45m (LxWxH)) **or equivalent to Standard ISO 40feet container.**

Shall read now:

- Container module size: 12,192m x 3,3m x 2.896m (LxWxH) (internal dimensions: 11,85m x 3m x 2,45m (LxWxH)) **or equivalent to Standard ISO 40feet container.**

If contractors decide to offer a 40-foot standard ISO container with a width of ~2.45m, then they must make sure that the racks are movable. They must allow a minimum space of 50cm on the back side of the racks, in order to ensure that the racks can be accessed.

For container module size: 12,192m x 3,3m x 2.896m (LxWxH) (internal dimensions: 11,85m x 3m x 2,45m (LxWxH)), the type of rack used (static/movable) is at the discretion of the Contractor. In either case, they must allow for a minimum space of 50cm on the back side of the racks, in order to ensure that the racks can be accessed.