



**EUROPEAN UNION RULE OF LAW MISSION IN KOSOVO**

**EULEX KOSOVO**

Ndertesë Farmëd  
"Muharrem Fejza" p.n.  
Lagja e Spitalit  
10 000 Pristina, Kosovo  
Tel: + (386) 43 78 2000  
<http://www.eulex-kosovo.eu>

**CLARIFICATIONS (2)**

**PUBLICATION REFERENCE: EuropeAid/131701/D/SUP/XK/Framework contract for the Supply of Generators and Spare Parts (PROC/283/11)**

**Questions regarding Annex II - Technical Specifications**

No	ITEM	Question	Answer
1	N/A	Generators have to be outdoor or indoor! Because it is not specified in dossier, we need to know do they have to be covered  Direct question is do they have to be covered or non covered generators???	The generators, in a silent canopy (64 – 70 dBA at 7 m.) will be installed outside of the buildings. (Please refer to Annex II – Technical Specifications Point 4 of Mandatory Specifications. )